

Thank you for participating in ADEM's Lead Testing in Child Care Facilities and Schools Program, a voluntary program funded by an EPA Grant under the Water Infrastructure Improvements for the Nation (WIIN) Act.

Our laboratory has analyzed the sample(s) submitted for your facility and determined that none of them exceeded the Action Level of 0.02 mg/l of lead. The results are shown in the table below: \

ELC Central Office

Location	Result (mg/L)	Description	Comments
ELC-Prep Sink	0.000617	Original	
ELC-Rinse Room	0.000189	Original	
ELC-Bathroom	0.000555	Original	
Nurse Station	0.000989	Original	

Eufaula Elementary School

Location	Result (mg/L)	Description	Comments
Boys Restroom 4th Grade	0.00103	Original	
Boys Restroom 3rd Grade	<MDL	Original	
Art Room 502	<MDL	Original	
Room 309	<MDL	Original	
Kitchen Prep Sink	0.00024	Original	
Special Ed - Room 404	<MDL	Original	
Boys Restroom 3rd Grade	0.000317	Original	
Nurses Station	0.00401	Original	

Eufaula High School

Location	Result (mg/L)	Description	Comments
Lunchroom - Prep Sink #1	0.000353	Original	
Lunchroom - Wash Sink	<MDL	Original	
Main Hallway - Boys Restroom	0.000232	Original	
Nurses Station	0.00139	Original	
Health Room	0.00301	Original	
Special Education - Kitchen	0.00048	Original	
Art Room	0.000669	Original	
Ag Room Hand Sink	0.000949	Original	

Admiral Moorer Middle School (AMMS)

Location	Result (mg/L)	Description	Comments
Concession Sink	0.000792	Original	
Boys Restroom- Gym	0.000199	Original	
Art Room Sink	0.00223	Original	
Boys Restroom - Middle Wing	0.000521	Original	

## Eufaula Head Start

Location	Result (mg/L)	Description	Comments
Pre K Room 808	<MDL	Original	
Pre K Room 807	<MDL	Original	
Boys Restroom	<MDL	Original	
Girls Restroom	<MDL	Original	
Central Office Girls Restroom East Wing	<MDL	Original	
Central Office Boys Restroom	<MDL	Original	
Central Office Girls Restroom	0.000277	Original	
Central Office Boys Restroom	0.000879	Original	

## Eufaula Primary

Location	Result (mg/L)	Description	Comments
Pre Sinks - Kitchen	0.000688	Original	
Nurse Station	0.0004	Original	
Room 309 1st Grade	0.000796	Original	
Room 501 Kindergarten	0.00147	Original	
Special Education Sink	0.00122	Original	
Boys Restroom 2nd Grade	0.000256	Original	
Boys Restroom Side Hall	0.000366	Original	
Century 21 Boys Restroom	0.000633	Original	